

**Levi Water Supply Corporation
Falls County
Water Plant**

**ADDENDUM NO. 4
August 18, 2026**

The construction plans and specifications for the Levi Water Supply Corporation Waterline Improvements, on which bids are to be received until 2:00 P.M. on Tuesday, August 25, 2026 are hereby modified as follows:

Microsoft Teams Meeting Link for Bid Opening:

<https://teams.microsoft.com/meet/256487117387066?p=UvRO6SK6MkClesTs15>

Meeting ID: 256 487 117 387 066 Passcode: Br3oB2vJ

Microsoft Teams Meeting Call-in Number for Bid Opening: 1 806-368-4374

Phone conference ID: 852 923 304#

1. Refer to Sheets CM-01 and EM-01 of the Plans for Check Valve Fittings. Check Valves shall be ASME Class 125/150 and shall be APCO CSD Slanting Disc Check Valves as manufactured by Dezurik or approved equal.
2. Refer to Sheet CM-01 of the Plans for Air Release Valve (B). The air and vacuum release valves shall be APCO Series 200 or approved equal.
3. Refer to Sheet CM-01 of the Plans for Pressure Relief Valve (R). The Pressure Relief Valve on the Well Pump Discharge Header shall be removed from the plans. The spool piping upstream from the flow meter (D) shall be extended to account for the removal of the Pressure Relief Valve.
4. Bidders shall acknowledge receipt of this Addendum in the space provided in the proposal and on the outer envelope of their bid.

Ginger R. Tolbert

8/18/2026

Ginger R. Tolbert, P.E.

Date

Kasberg, Patrick & Associates, LP

11 South 2nd Street

Temple, Texas 76501

